

Product Data Sheet

Astro Coat - Spray Grade

Revision 8 - 12th March 2021



Astro Coat - Spray Grade

Ablative Coating

- CE Marked, UL-EU Listed & Certifire Approval.
- Fire Resistance Testing to EN 1366-3 : 2009.
- Fire Classification to EN 13501-2.
- Fire Resistance Testing to BS 476 Part 20 : 1987.
- Air Permeability testing to EN 1026.
- Acoustic Isolation testing to EN 10140.



Product Description

Astro Coat Spray Grade Ablative Coating is a highly advanced flexible coating for use when installing the Astro Batt System. The Astro Coat Spray Grade Ablative Coated is used to seal in the Astro Batt to reinstate the fire resistance performance of wall and floor constructions where apertures are penetrated by single or multiple services.

Astro Coat Spray Grade Ablative Coating is tested and Certified as part the Astroflame Fire Stopping range. The Astro Coat Spray Grade Ablative Coating when used as part of the Astro Batt System can be installed across a variety services and substrates including,

- Flexible and Rigid Walls
- Rigid Floors
- Multi-Service penetrations
- Blank Openings
- Head of Walls

 2812
Astroflame Fireseals Ltd Unit 8 The IO Centre Stephenson Road Segensworth, Fareham Hampshire PO15 5RU 20 2812-CPR-JA5026
ETA-20/1091 ETAG 026 - Part 1 ETAG 026 - Part 2 ASTRO BATT ASTRO COATING "see ETA-20/1091 for relevant characteristics"

Product Availability

Astro Coat - Spray Grade - Sold per 5 Kilo Tub.

Product Code	Product Description
AFBCOAT5L	Astro Coat - Spray Grade

Compliance

Astro Coat is manufactured in the EU, meeting the highest quality standard in compliance to ISO EN 9001. For fire test certification and Technical advice contact Astroflame technical department.

To Order & Specify

Please contact us and quote the following information - Quantity / Product Code / Product Description
Typical example:- 10 / AFBCOAT5L / Astro Coat

>> Tel: [01329 844 500](tel:01329844500) or >> Email: sales@astroflame.com

Installation

We have technical representatives who provide assistance in the selection and specification of the products on this site and should be consulted for exact installation and product suitability. Ensure an early engagement with ourselves, designers, main contractor and specialist installers before any installation. Other trades and/or manufacturers may need to be consulted. For in-depth information, specification and technical advice please call our Head Office on tel [01329 844 500](tel:01329844500) or email sales@astroflame.com

Maintenance

All interested parties, designer, specifier, main contractor and specialist installers should provide access to allow the fire stopping seals to be regularly inspected and maintained, as well as records kept of such maintenance at minimum periods of 12 months, as required by the Regulatory Reform Order, and repaired if necessary. Reference should be made to ASFP TGD 17 – Code of Practice for the Installation and Inspection of Fire Stopping.

Competency

It is vital that those entrusted to design or install a fire stopping product have the necessary levels of competence to undertake the task professionally and thoroughly. The level of competency required will be commensurate with the expected complexity of the building. All designers must eliminate, reduce or control foreseeable risks that may arise during installation, construction or maintenance when preparing or modifying designs. Clients should ensure that the principal designer and principal contractor carry out their duties under CDM regulations. The ASFP foundation course in passive fire protection provides essential knowledge as part of demonstrating competency and understanding in this key fire protection specialism.

Additional Notes

Please refer to the ETA sheet for fields of application for this product. For further information on installation requirements please refer to the manufacturer of the services and the wall/floor specification to ensure the compatibility of this product, if in doubt please contact the technical team with services and wall/floor specification on: T: [01329 844 500](tel:01329844500) or E: sales@astroflame.com

Health and Safety

Please see (SDS) Safety Data sheet - This can be requested from our sales team T: [01329 844 500](tel:01329844500) or E: sales@astroflame.com

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME (FIRE SEALS) LTD has no control over the specific application or installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product based on the products limitation of applications and that the product is fit for purpose for their intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROFLAME (FIRE SEALS) LTD, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice. If you are in any doubt as to the suitability of this product for your intended application please contact our technical team on 01329 844500 or email sales@astroflame.com and we will contact you.